

To: dpeer@mlcorporateventures.com[dpeer@mlcorporateventures.com];
Ryan.rupp@millelacsband.com[Ryan.rupp@millelacsband.com]; Andrew Boyd - Mille Lacs
(andrew.boyd@millelacsband.com)[andrew.boyd@millelacsband.com]
From: Restaino, Mark
Sent: Fri 5/26/2017 7:07:57 PM
Subject: Test of the Automatic Tank Gauge

I took a look at the regulations and the Automatic Tank Gauge is to be tested annually. My suggestion is that you do this test along with the automatic line leak detection functionality test.

-Mark

Mark Restaino

Underground Storage Tanks Section
Land and Chemicals Division
U.S. EPA Region 5
77 W. Jackson Blvd. (LR-17J)
Chicago, IL 60604
Phone: (312) 886-0394
Fax: (312) 582-5872